



Hostalets de Balenyà, 2nd September 2010

Industrias Gonal Hispania S.L. hereby **certifies** that :

Our ducting systems for extraction and ventilation of air are produced with PVC rigid compound and fulfill following specifications :

<u>Technical specifications</u>	<u>Unit</u>	<u>Value</u>
Specific gravity	gr/cm ³	1,68
Tensile strenght	Mpa	> 42
Elongation at break	%	> 100
Hardness Shore D		80
Vicat softening temperature	°C	82
Classified		M1
Lead	%	3
Temperatures level	°C	-5 °C to +70 °C
Standard colour :		white

All processes related to manufacturing, warehousing and delivery of this products are made under procedures that marks the 9001/2000 Standard

Mr. Francisco Guirao
Technical Director

Nombre de archivo: ducting CERTIFICATE
Directorio: C:\Documents and Settings\Usuario\Mis documentos
Plantilla: C:\Documents and Settings\Usuario\Datos de
programa\Microsoft\Plantillas\Normal.dotm
Título: Hostalets de Balenyà, 2nd September 2005
Asunto:
Autor: computer
Palabras clave:
Comentarios:
Fecha de creación: 03/09/2010 12:52:00
Cambio número: 5
Guardado el: 03/09/2010 13:29:00
Guardado por: Computer
Tiempo de edición: 4 minutos
Impreso el: 03/09/2010 13:29:00
Última impresión completa
Número de páginas: 1
Número de palabras: 120 (aprox.)
Número de caracteres: 661 (aprox.)